

Certificate of compliance

Applicant: SunSynk Ltd.

Flat A, 3/F Wai Yip Industrial Building, 171 Wai Yip Street, Kwun Tong,

Hong Kong

Product: Photovoltaic (PV) and battery inverter

Model: SUNSYNK-3.6K-SG03LP1

SUNSYNK-5K-SG03LP1

Inverter for single-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

Applied rules and standards:

EN 50549-1:2019

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

DIN V VDE V 0126-1-1:2006 (4.1 Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid

Commission Regulation (EU) 2016/631 of 14 April 2016

Establishing a network code on requirements for grid connection of generators (NC RFG).

Type approval for generation units to use in Type A plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Certification body

Report number: ASUE-ESH-P23091087

Certificate number: U23-0829

Certification Program:

NSOP-0032-DEU-ZE-V01

Date of issue: 2023

2023-09-22

DAKKS

Deutsche
Akkreditierungsstelle
D-ZE-12024-01-00

Alf Assenkamp

Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

Testing laboratory accredited according to DIN EN ISO/IEC 17025

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH



Annex to the EN 50549-1 certificate of compliance No. U23-0829

м	,	j)	3	ĪΧ

Extract from test report according to EN 50549-1

No. ASUE-ESH-P23091087

Extract from test report accord	140.	NO. AGGE-EGIT-1 23031007							
Type Approval and declaration of compliance with the requirements of EN 50549-1 and Commission Regulation (EU) 2016/631 of 14 April 2016									
Manufacturer / applicant	SunSynk Ltd. Flat A, 3/F Wai Yip Industrial Building, 171 Wai Yip Street,Kwun Tong, Hong Kong								
Micro-generator Type	Photovoltaic and battery inverter								
	SUNSYNK-3.6K- SG03LP1	SUNSYNK-5K- SG03LP1							
MPP DC voltage range [V]	150-425	150-425							
Input DC voltage range [V]	370 (125-500)	370 (125-500)							
Input DC current [A]	13/13	13/13							
Output AC voltage [V]	230, 50/60Hz	230, 50/60Hz							
Output AC current [A]	15,7	21,7							
Output power [W]	3600	5000							
Battery DC voltage range [V]	48 (40-60)	48 (40-60)							
Battery charge current [A]	90	120							
Battery discharge current [A]	90	120							
Firmware version	Ver2131								

Description of the structure of the power generation unit:

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on the inverter bridge and two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.

Note:

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019 Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.